2024 Annual Water Quality Report Town of Moorcroft PWS WY5600037

Spanish (Espanol)

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) for Town of Moorcroft as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source consists of six ground water wells drawn from the Lance and Foxhills formation and one from the Madison formation.

Source water assessment and its availability

Our source water assessment is available by visiting the Clerk's Office at Town Hall 104 North Big Horn Moorcroft, WY.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you would like to learn more, please attend any of our regularly scheduled meetings. The meetings are held every 2 weeks on Wednesday night at the Moorcroft City Hall 104 North Big Horn. Check website for times and agenda.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit <u>www.epa.gov/watersense</u> for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.

- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Significant Deficiencies

Violation period: 6/1/2023 to 2024

We failed to properly respond to a significant deficiency in our water system.

Corrections from a sanitary survey have now been completed. We are submitting pictures to EPA for approval.

- The air vent and access hatch for Tank ST01 Moorcroft Storage Tank must be inspected and the structure/condition compared to the Tech Tips for Finished Water Storage Facilities.
- The air vent and access hatch for Tank ST02 Madison Storage Tank must be inspected and the structure/condition compared to the Tech Tips for Finished Water Storage Facilities.
- Well WL03 Well #6 must be fitted with a functioning sanitary seal that is tightly bolted and does not allow contamination to enter the well.
- Well WL05 Well #9 must be fitted with a functioning sanitary seal that is tightly bolted and does not allow contamination to enter the well.
- Well WL06 Well #10 must be fitted with a functioning sanitary seal that is tightly bolted and does not allow contamination to enter the well.

Additional Information for Lead

The system inventory includes lead service lines. Contact Moorcroft Town Hall

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. MOORCROFT, TOWN OF is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact MOORCROFT, TOWN OF (Public Water System Id: WY5600037) by calling 307-756-3526 or emailing publicworks@townofmoorcroft.com. Information on lead in drinking water, testing methods, and

steps you can take to minimize exposure is available at http://www.epa.gov/safewater/lead. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Moorcroft is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

			Detect	Ra	nge			
Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	In Your Water	Low	High	Sample Date	Violation	Typical Source
Disinfectants & Disinfection By-Products								
(There is convincing e	(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)							l of microbial contaminants)
Chlorine (as Cl2) (ppm)	4	4	1.16	0.06	1.16	2024	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	3.5	NA	NA	2024	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	3.3	NA	NA	2024	No	By-product of drinking water disinfection

				Detect	Range						
Contaminants	MCLG or MRDLG	T	CL, ſ, or RDL	In Your Water	Low	High	Sample Date	Violatio	n	Typical Source	
Inorganic Contamina	ants				1		1	1			
Arsenic (ppb)	0		10	2	NA	NA	2023	No	Runof from g	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Fluoride (ppm)	4		4	1.5	NA	NA	2023	No	Water strong fertiliz	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Nitrate [measured as Nitrogen] (ppm)	10		10	0.2	NA	NA	2024	No	Leachi sewag	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
Selenium (ppb)	50		50	5	NA	NA	2023	No	metal i natura	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines	
Sodium (optional) (ppm)	NA			101	NA	NA	2023	No			
Radioactive Contam	inants										
Alpha emitters (pCi/L)	0		15	5.7	NA	5.7	2021	No	Erosio	n of natural deposits	
Radium (combined 226/228) (pCi/L)	0		5	1.5	NA	NA	2021	No	Erosio	n of natural deposits	
Uranium (ug/L)	0		30	6.4	NA	NA	2021	No	Erosio	n of natural deposits	
				Ra	inge #Sample						
Contaminants	MCLG	AL	Your Water	Low	High		ceeding AL	Sample Date	Exceeds AL	Typical Source	
Inorganic Contamina	ants										
Copper - action level at consumer taps (ppm)	1.3	1.3	0.111	0.023	0.11		0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	3	NA	3		0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Violations and Exceedances

Unit Descriptions						
Term	Definition					
ug/L	ug/L : Number of micrograms of substance in one liter of water					
ppm	ppm: parts per million, or milligrams per liter (mg/L)					
ppb	ppb: parts per billion, or micrograms per liter (μ g/L)					
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)					
NA	NA: not applicable					
ND	ND: Not detected					
NR	NR: Monitoring not required, but recommended.					

Important Drinking Water Definitions					
Term	Definition				
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.				
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.				
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.				
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.				
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.				
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.				
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.				
MNR	MNR: Monitored Not Regulated				
MPL	MPL: State Assigned Maximum Permissible Level				

TT Violation	Explanation	Length	Health Effects Language	Explanation and Comment
Ground Water Rule violations	Failure to address deficiency	6/01/2023 to present	During the 2020 Sanitary Survey of The Town of Moorcroft drinking water system, there were some deficiencies found. On two of the town's wells, the sanitary seal was reported to be missing from the top of the well head, the sanitary seal was also reported missing at the Madison Well, and the seals for the tank hatches at Madison and the Blue Tank were not inspected.	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

TT Violation	Explanation	Length	Health Effects Language	Explanation and Comment
			The wells in question have been checked, and found to have functioning seals, however, to satisfy the requirements set forth by the EPA, new seals, bonnets, and retainer rings have been ordered and are to be installed.	
			The seals on the water storage tanks have been inspected by our tank divers and are in good condition.	

For more information please contact:

Contact Name: Hiser, April Address: 104 North Big Horn Ave, PO Box 70 Moorcroft, WY 82721 Phone: 307-756-3526